

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

At time of the inspection, it was observed that the cabinet under sink in classroom 068 is water damaged. The air conditioner in computer lab is not working (work order already done)
Replace water damaged cabinet under sink .
Repair damaged air conditioner in computer lab.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

It was observed that some light bulbs in classrooms 085,072,068,061 are burned out.
Replace burned out light bulbs in classrooms.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Maria Adrover (047452)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Suzet Hernandez
Date: 7/2/2024

Inspector Signature:

Handwritten signature of Maria Adrover.

Client Signature:

Handwritten signature of Suzet Hernandez.