



# MIAMI-DADE FIRE RESCUE DEPARTMENT INSPECTION REPORT FIRE PREVENTION BUREAU

9300 NW 41ST STREET, DORAL, FLORIDA 33178-2424  
(786) 331-4800



Permit Number: **00121-00194**

Date: **December 10, 2024**

**DADE COUNTY PUBLIC SCHOOLS - DCPS**  
1450 NE 2 AVE ROOM 602  
MIAMI, FL 33132

Permit Type: **Education**  
Permit Use: **K-12 Public School**  
Permit Status: **Inspected / N.O.V. (30)**  
Status Date: **12/10/2024**

Reviewed By: **TONYA WILLIAMS**  
Inspected By: **TONYA WILLIAMS**  
Phone: **305-561-9441**  
Email: **tonya.williams@miamidade.gov**

Inspected Address:

**DCPS CALUSA ELEMENTARY SCHOOL**  
9580 - 9580 W CALUSA CLUB DR  
MIAMI, FL 33186

### NOTICE OF VIOLATION AND ORDER TO CORRECT

The hazards noted herein are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code and are deemed to be threats to life safety and/or property. You are hereby ordered to comply with the corrective measures prescribed.

**APPEALS:** Any person who believes they were incorrectly issued a notice of violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami- Dade County Fire Prevention and Safety Appeals Board by filing a written notice **within 30 days** of receiving the Notice of Violation and Order to Correct. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: <http://www.miamidade.gov/fire/request-appeal.asp>. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal. Section 14-36, Code of Miami-Dade County.

### Violation(s)

1.	Created	Comply By	Code	Status
	12/10/2024	1/9/2025	FFPC 8th Edition, NFPA 1: 50.6.2.1	Pending Correction

**Violation:** Failure to have cooking hood fire suppression system inspected.

**Correction:** Have cooking hood fire suppression system inspected every 6 months by a licensed company, provide a current inspection and testing report; clear of any deficiencies or impairments.

**Comment:** SERVICE, TAG AND PROVIDE CURRENT SEMI-ANNUAL HOOD SUPPRESSION REPORT

**Note:** A Life Safety Permit required by Section 14-39, Code of Miami-Dade County, to operate the above named occupancy will be issued upon correction of all outstanding violations and payment of fees assessed. **Failure to obtain the required Life Safety Permit will result in enforcement actions including fines, citations, liens and/or orders to cease and desist operation.**

Name: **Susana Chueca**  
Title:



How did we do?  
We would like to hear about it.  
Scan the QR code to complete a survey.